



ConduPlug™ Technical Specifications

Physical Properties:

Property	Typical Value	Unit	Test Method
Dry Density (powder)	1021	kg/m ³	SAE Inc. Standard 106 (dependent on compaction)
	1.021	g/cm ³	
	63.7	lbs/ft ³	
Wet Density (hardened state)	1730	kg/m ³	SAE Inc. Standard 106
	1.73	g/cm ³	
	108	lbs/ft ³	
Slurry Density (3 US Gallons/55 lb bag)	1529	kg/m ³	SAE Inc. Standard 106
	1.529	g/cm ³	
	95.4	lbs/ft ³	
Dry Volume (powder)	0.023	m ³ /55 lb bag	SAE Inc. Standard 106
	0.802	ft ³ /55 lb bag	
Slurry Volume	0.025	m ³ /55 lb bag	SAE Inc. Standard 106
	0.886	ft ³ /55 lb bag	
Hygroscopic Property (Water Absorption)	25.4	%	SAE Inc. Standard 110
Water Permeability	2.0 x 10 ⁻⁸	cm/sec	ASTM 5084 (2.6 psi)
Compressive Strength	27.6	MPa	CAN/CSA.A23.2-14
	4003	psi	
Electrical Corrosion Resistance Copper	95 - 100	%	SAE Inc. Standard 100
Compatibility Copper	Yes		SAE Inc. Standard 100
Environmental Impact	Neutral		Ontario Regulation 558/00 (Leachate Testing) and NSF/ANSI 60
Carbon Consumption Rate	0.5	kg/amp-year	SAE Inc. Standard 111

Electrical Properties:

Property	Typical Value	Unit	Test Method
Resistivity	2.8 – 5.0	Ω·cm	Modified ASTM G187-05
Conductivity	0.2 – 0.4	S/cm	Modified ASTM G187-05

Material Properties:

Property	Typical Value	Unit	Test Method
Physical State	Grey Powder		
Odor	None		
Setting Time	24	hours	
Cure Time	28	days	

SAE Inc. Canada

691 Bayview Dr. Barrie, ON L4N 9A5, Canada
 T: 705.733.3307 • F: 705.733.1218 • TF: 1.877.234.2502
 info@saeinc.com • www.saeinc.com

SAE Inc. USA

14 Tammie Lee Lane, Los Lunas, NM, 87031 USA
 T: 505.866.8901 • TF: 1.877.234.2502
 info@saeinc.com • www.saeinc.com



IEC 62561-7 Leachate Testing Results:

Procedures in EN 12457-2 and EN 12506 standards were followed. Testing was performed by Powertech Labs Inc.

Ion	Concentration (mg/L)	Amount Released (%)
Aluminum	0.68	0.000068
Barium	1.74	0.000174
Zinc	0.06	0.000006

Leachate (TCLP) Results:

Leachate Data (TCLP Procedure) based on Regulation 558 performed by Testmark Laboratories Ltd.

Constituent	ConduPlug™ TCLP Concentration (mg/L)	USEPA Maximum Contaminant Level (mg/L)
Arsenic	< 0.01	0.010
Barium	0.383	2.000
Boron	0.158	2.000 [†]
Cadmium	< 0.001	0.005
Lead	< 0.01	0.015
Mercury	0.001	0.002
Selenium	< 0.01	0.050
Silver	< 0.01	0.100*
Uranium	< 0.01	0.030
Fluoride	< 0.01	2.000*
Nitrate (as Nitrogen)	< 0.01	10.000
Nitrite (as Nitrogen)	< 0.05	1.000
Cyanide	0.05	0.200

† No MCL established; value shown is USEPA's Lifetime Drinking Water Health Advisory.

* No MCL established; value shown is USEPA's secondary drinking water standard.

Note: < denotes less than method detection limit (MDL).

NSF/ANSI 60:

ConduPlug™ meets NSF/ANSI 60: Drinking Water Treatment Chemicals – Health Effects.

<http://info.nsf.org/Certified/PwsChemicals/Listings.asp?Company=C0169859&>

Updated: June 26, 2018

SAE Inc. Canada

691 Bayview Dr. Barrie, ON L4N 9A5, Canada
 T: 705.733.3307 • F: 705.733.1218 • TF: 1.877.234.2502
 info@saeinc.com • www.saeinc.com

SAE Inc. USA

14 Tammie Lee Lane, Los Lunas, NM, 87031 USA
 T: 505.866.8901 • TF: 1.877.234.2502
 info@saeinc.com • www.saeinc.com